

Row Number	REF	BLDG	ROOM	DESCRIPTION	Status	Required Action
<b>Conniston MS Outstanding Punchlist Items</b>						
146	NFPA	2	282	Close and seal gaps around flourescent light fixture in corridor to prevent the spread of smoke and fire	WGM	D & D
147	NFPA	2	294	Seal penetration in enclosure walls or ceilings to prevent spread of fire and smoke in room 2-202	WGM	D & D
65	NFPA 101, 7.2.2.3.6	2	009	Adjust steps to make risers equal	WGM	Eastern Construction
66	NFPA 101, 7.2.2.3.6	2	010	Adjust steps to make risers equal	WGM	Eastern Construction
78	NFPA 13	3	190	Provide additional fire sprinkler heads to provide coverage for room - coverage is blocked by ductwork	WGM	J W Fire Sprinkler
81	NFPA 13	5	002	Provide additional fire sprinkler heads to provide coverage for room - coverage is blocked by ductwork	WGM	J W Fire Sprinkler
82	NFPA 13	2	281	Relocate fire sprinkler head from above hot water heater to provide full coverage for custodial room	WGM	J W Fire Sprinkler
143	NFPA	1	108	Adjust level of fire sprinkler head to be a minimum 1" below escutcheon	WGM	J W Fire Sprinkler
148	NFPA	3	006	Adjust level of fire sprinkler head to be minimum 1" below escutcheon adjacent to 3-206	WGM	J W Fire Sprinkler
152	NFPA	3	202	Adjust level of fire sprinkler head to be minimum 1" below escutcheon	WGM	J W Fire Sprinkler
155	NFPA	3	213	Adjust level of fire sprinkler head to be minimum 1" below escutcheon	WGM	J W Fire Sprinkler
158	NFPA	4	201	Provide cover on exposed electrical junction box in ceiling	WGM	Terry's Electric
159	NFPA	5	104	Provide cover on exposed electrical junction box adjacent to 5-104H	WGM	Terry's Electric
163	NFPA	5	104	Complete installation of kitchen bell and provide cover plate	WGM	Terry's Electric
164	NFPA	6	203	Provide cover on exposed electrical junction box at ceiling	WGM	Terry's Electric
20	FBC, 11-4.7.7	00	9599	Provide tactile warning surface along curb cut in sidewalk adjacent to bus loop	WGM	WGM to investigate
79	NFPA 13	3	191	Verify and label walls as 2 hour rated or provide fire sprinkler coverage (gaps between bottom of wall and floor)	WGM	WGM to investigate